



Greenwich System
2016 Lead Compliance Testing Results
System is in Compliance

Rank	Collection Date	Lead Results (ppb)
1	09/06/16	None Detected
2	09/13/16	None Detected
3	09/14/16	None Detected
4	09/14/16	None Detected
5	09/14/16	None Detected
6	09/14/16	None Detected
7	09/15/16	None Detected
8	09/15/16	None Detected
9	09/15/16	None Detected
10	09/15/16	None Detected
11	09/15/16	None Detected
12	09/15/16	None Detected
13	09/16/16	None Detected
14	09/16/16	None Detected
15	09/16/16	None Detected
16	09/16/16	None Detected
17	09/16/16	None Detected
18	09/16/16	None Detected
19	09/16/16	None Detected
20	09/16/16	None Detected
21	09/16/16	None Detected
22	09/16/16	None Detected
23	09/16/16	None Detected
24	09/16/16	None Detected
25	09/16/16	None Detected
26	09/16/16	None Detected
27	09/16/16	1
28	09/13/16	2
29	09/15/16	2
30	09/16/16	2
31	09/16/16	3
32	09/16/16	3

PWS ID#: CT0570011