



Seymour - Valley System
2017 Lead Compliance Testing Results
System is in Compliance

Rank	Collection Date	Lead Results (ppb)
1	08/17/17	None Detected
2	08/17/17	None Detected
3	08/17/17	None Detected
4	08/17/17	None Detected
5	08/17/17	None Detected
6	08/17/17	None Detected
7	08/17/17	None Detected
8	08/17/17	None Detected
9	08/17/17	None Detected
10	08/17/17	None Detected
11	08/17/17	None Detected
12	08/17/17	None Detected
13	08/17/17	None Detected
14	08/17/17	None Detected
15	08/17/17	None Detected
16	08/17/17	None Detected
17	08/17/17	None Detected
18	08/17/17	None Detected
19	08/29/17	None Detected
20	09/14/17	None Detected
21	08/17/17	1
22	08/17/17	2
23	08/17/17	2
24	08/17/17	2
25	08/17/17	3
26	08/17/17	3
27	08/17/17	4
28	09/01/17	5
29	08/17/17	12
30	08/17/17	42

PWS ID#: CT1240011