

Aquarion Water Company
PFAS Sampling Results

Town/City: Bridgeport Metro

(Easton, Fairfield, Monroe, Newtown, Norwalk-Saugatuck Shores, Redding, Shelton, Stratford, Trumbull, Weston, Westport and Wilton)

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL	Current	Other PFAS
								PFAS (5)	CT DPH Guideline	Tested PFBS
Bridgeport Metro	Trap Falls Reservoir, POE	2019	5	ND	ND	ND	ND	5	70	ND
	Hemlocks Reservoir, POE	2019	2	ND	ND	ND	ND	2	70	ND
	Easton Lake Reservoir, POE	2019	3	ND	ND	ND	ND	3	70	ND
	Canal Street Wells, POE	2019	4	5	ND	4	ND	13	70	ND
	Coleytown Wells, POE	2019	4	4	ND	ND	ND	8	70	ND
	Housatonic Wells, POE - NOT IN SERVICE	2019	-	-	-	-	-	No Sample	70	-

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.