

Aquarion Water Company
PFAS Sampling Results

Town/City: Brookfield

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Brookfield Main	Brookfield Wells, POE	2019	4	ND	ND	ND	ND	4	70	ND
	Brook Acres Wells, POE	2019	3	ND	ND	ND	ND	3	70	ND
	Towne Brooke Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Brookwood	Brookwood Wells, POE	2019	4	ND	ND	ND	ND	4	70	ND
Butternut	Butternut Wells, POE	2019	4	ND	ND	ND	ND	4	70	ND
Hickory Hills	Hickory Hills Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Indian Fields	Indian Fields Wells, POE	2019	5	ND	ND	ND	ND	5	70	ND
Western Brookfield	Western Brookfield Wells, POE	2019	9	10	3	4	ND	26	70	ND
	Western Brookfield Wells, POE	March 2020	6	8	ND	3	ND	17	70	3

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer