

Aquarion Water Company
PFAS Sampling Results

Town/City: New Fairfield

All Results Reported as parts per trillion (ppt)								TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA			
Ball Pond	Gilotti Wells, POE	2019	6	5	ND	ND	ND	11	70	ND
	Renda Wells, POE	2019	7	12	2	3	ND	24	70	ND
	Renda Wells, POE	Feb. 2020	6	6	ND	2	ND	14	70	4
	Biggs Wells, POE	2019	8	19	ND	4	ND	31	70	3
	Biggs Wells, POE	Feb. 2020	7	18	ND	4	ND	29	70	2
Birches	Birches Wells, POE	2019	2	ND	ND	ND	ND	2	70	ND
Dunham Pond	Dunham Pond Wells, POE	2019	4	ND	ND	ND	ND	4	70	ND
Fieldstone Ridge	Fieldstone Ridge Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Interlaken	Interlaken Well, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Oakwood Acres	Oakwood Acres Wells, POE	2019	9	10	2	3	2	26	70	ND
	Oakwood Acres Wells, POE	2019	6	6	ND	ND	ND	12	70	ND
	Oakwood Acres Wells, POE	Feb. 2020	7	7	ND	3	ND	17	70	ND
Possum Ridge	Possum Ridge Wells 2&3, POE	2019	2	ND	ND	ND	ND	2	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer