

Aquarion Water Company
PFAS Sampling Results

Town/City: New Milford

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Carmen Hill	Carmen Hill Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Dean Hieghts	Dean Heights Wells, POE	2019	4	5	ND	ND	ND	9	70	ND
Forest Hills Estates	Forest Hills Well #1A, POE	2019	3	ND	ND	3	ND	6	70	ND
	Forest Hills Well #2, POE	2019	3	ND	ND	ND	ND	3	70	ND
Laurel Ridge/Laurel View	Laurel Ridge Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Meadowbrook	Meadowbrook Wells, POE	2019	4	ND	ND	ND	ND	4	70	ND
New Milford Main	Peagler Well #1, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
	Peagler Wells #2/3, POE	2019	2	ND	ND	ND	ND	2	70	ND
	Indian Field Wells #4/5/6, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Park Glen	Park Glen Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Pleasant View	Pleasant View Wells, POE	2019	2	ND	ND	ND	ND	2	70	ND
Twin Oaks	Twin Oaks Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.