

Aquarion Water Company
PFAS Sampling Results

Town/City: Ridgefield

		All Results Reported as parts per trillion (ppt)						TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA			
Craigmoor	Craigmoor Well, POE	2019	5	9	3	4	ND	21	70	ND
		2019	6	6	3	ND	ND	15	70	ND
		Feb. 2020	5	6	ND	3	ND	14	70	2
Ridgefield Knolls	Ridgefield Knolls Wells, POE	2019	4	6	ND	ND	ND	10	70	ND
Ridgefield Main	Branchville Pump Station, Distribution Point	2019	3	ND	ND	ND	ND	3	70	ND
	Oscaleta Wells, POE	2019	5	ND	ND	ND	ND	5	70	ND
	Beechwood Wells, POE	2019	12	ND	8	ND	ND	20	70	ND
	Beechwood Wells, POE	June 2020	9	ND	5	ND	ND	14	70	ND
	North St. Wells, POE	2019	4	5	ND	ND	ND	9	70	ND
	Beechwood Wells, Raw	2020	10	2	4	ND	ND	16	70	4
Scodon	Scodon Wells #2&3, POE	2019	3	ND	ND	ND	ND	3	70	ND
	Scodon Wells #4&7, POE	2019	2	ND	ND	ND	ND	2	70	ND
Turner Hill-Barnum	Turner Hill-Barnum, Distribution Point	2019	4	ND	ND	ND	ND	4	70	ND
Turner Hill-McKeon	Turner Hill-McKeon, Distribution Point	2019	4	ND	ND	ND	ND	4	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer