

**Aquarion Water Company of Massachusetts  
PFAS Sampling Results**

Town/City: Oxford

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL	MASSDEP	PFDA	TOTAL	MASSDEP	Other PFAS Tested		
								PFAS (5)	2019 Guideline		PFAS (6)	2020 Guideline	PFBS	PFHxA	PFTA
Oxford	No. Main St Well #1, POE	2019 Q4 (October)	1	1	ND	ND	ND	2	70	ND	2	20	1	ND	ND
	No. Main St Well #2, POE	2019 Q4 (October)	1	1	ND	1	ND	3	70	ND	3	20	1	ND	ND
	Nelson St Wells #3, POE	2019 Q4 (October)	2	1	1	1	ND	5	70	ND	5	20	1	ND	ND
	Nelson St Wells #3, Raw	2020 Q2 (April)	2	ND	ND	ND	ND	2	70	ND	2	20	1	ND	ND

**Definitions:**

**ND** - Not Detected

**NT** - Not Tested

**Finished** - Sample collected after treatment while well is run to waste. No water entering the distribution system for customer consumption.

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.

**Raw** - Sample collected before treatment.