

Aquarion Water Company PFAS Sampling Results

Town/City: Danbury
Water System Name: Cedar Heights

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Cedar Heights Wells, POE	Jul. 2019	9		10		5		ND	
	Feb. 2020	11		11		5		ND	
	Aug. 2020	8		8		5		ND	
	Oct. 2020	11		13		8		ND	
	Feb. 2021	10		11		4		ND	
	Jun. 2021	10		11		6		ND	
	Aug. 2021	10		11		4		ND	
	Apr. 2022	9		10		4		ND	
Cedars Well, POE	Jul. 2019	9		9		4		ND	
	Feb. 2020	12		10		5		ND	
	Aug. 2020	8		7		4		ND	
	Oct. 2020	9		9		3		ND	
	Feb. 2021	9		9		4		ND	
	Jun. 2021	10		10		4		ND	
	Aug. 2021	11		13		3		ND	
	Apr. 2022	12		10		3		ND	

Footnotes:

* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022. A yellow highlighted value denotes a concentration greater than this new level.

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.